

Q&A

Tamarack Village Windows/Slider Doors

- 1) The specifications indicate that the windows are to be Energy Star rated. Can you confirm that this is the project requirement? For the Energy Star North Climate Zone, windows must achieve a U-Factor of 0.22 (your specifications currently call for 0.30) and a Solar Heat Gain Coefficient (SHGC) of 0.17. Meeting these performance requirements would typically require a triple-pane insulated glass unit (IGU).
 - a. Answer: We do not want triple-pane windows. Please remove the Energy Star requirement and make sure the windows meet U-Factor of .30.